

**NOTICE: THIS ADDENDUM CONTAINS IMPORTANT
INFORMATION THAT AFFECTS YOUR BID– PLEASE
RESPOND IMMEDIATELY**

PIERCE STREET PARK CONSTRUCTION PROJECT
CONTRACT NO. C15-1
CITY OF ALBANY, CA

ADDENDUM NO. 1 – April 21, 2016

The following questions were asked during the Pre-Bid Meeting on October 17, 2016:

Please clarify irrigation - will plans be provided?

There will be no irrigation installed. Plants will be planted with Driwater irrigation supplements and hand watered, as needed, by the contractor through the end of the maintenance period. Conduit, pull boxes and pull wire to be provided at the restroom building for future installation of an irrigation controller inside the building chase.

Specs say “water to be provided by City”. Please clarify.

Water is not provided by City. Contractor to coordinate with EBMUD for water meter installation.

Water for watering plants? Sources?

Contractor to arrange for water source at his expense to water in plantings.

Are there any special permits required for the project? What will the Contractor need to pay for?

The City requires that the contractor obtain a no fee encroachment permit for work in the City’s right-of-way.

This Addendum, consisting of two (2) pages, including this NOTICE shall become a part of Contract No. C15-1.

Every bidder shall acknowledge receipt of this Addendum by immediately signing below and returning this Addendum by email to jwalker@albanyca.org. The contractor is reminded that signing the acknowledgment of receipt of addenda in the Proposal is also required.

<p>The undersigned acknowledges receipt of this Addendum</p> <p>Name of Contractor: _____</p> <p>By (signature): _____ Title: _____</p> <p>Print name: _____</p>
