

**CITY OF ALBANY
PLANNING AND ZONING AGENDA
STAFF REPORT**

Agenda date: February 23, 2010
Prepared by: JB

ITEM/ **6a**

SUBJECT: **Planning Application 10-004. Design Review.**

The applicant is requesting Design Review approval to allow an approximately 213 sq. ft. addition to the first floor and a 23 square foot reduction to the second floor. The maximum height of the home will increase from approximately 17 feet to approximately 24 feet in height.

SITE: **1014 Ordway**

APPLICANT/

OWNER: **Michael Massoumi**

ZONING: **R-1 (Single-Family Residential)**

STAFF RECOMMENDATION

Staff recommends that the Planning and Zoning Commission approve the project, subject to the attached conditions of approval.

BACKGROUND/PROJECT DESCRIPTION

The subject property is a 3,850 sq. ft. lot with a 2,028 sq. ft. two-story, single-family home. The applicant is requesting Design Review approval to allow reconstruction of the first floor resulting in an approximately 213 sq. ft. addition, and 23 square foot reduction to the second floor. The maximum height of the home will increase from approximately 17 feet to approximately 24 feet in height. The home will maintain the Spanish-style design, but the roof will be changed from a flat roof to a front gable peak roof.

ENVIRONMENTAL ANALYSIS

Staff has determined that the proposed project is categorically exempt from the requirements of CEQA per Section 15303, "New Construction or Conversion of Small Structures" of the CEQA Guidelines, which exempts small additions.

DISCUSSION OF KEY ISSUES

Design Review

The existing home is a one-story with a garage and several habitable rooms below. The home features a Spanish architectural style with stucco finish, flat roof, small front porch and bay

window. The applicant proposed to reconstruct the first floor to expand the habitable area and raising the second floor 42 inches. In addition, the roof style would change to afffront-gable style roof with clay roof tiles. The proposed design is attractive, featuring many of the elements identified in the City's design guidelines, including cooper gutters, louvered attic vents, carriage style garage doors, consistent window style, and wood brackets supporting the front bay.

Off-Street Parking

The existing home has a one car garage. The proposed project keeps the one car garage, reducing it in size form 370 square feet to 310 square feet. Because the total net increase in square footage is less than 240 square feet, the requirement of a second off-street parking space is not triggered.

Attachments:

1. Analysis of Zoning Requirements
2. Findings and Conditions of Approval
3. Project Application & Plans

ATTACHMENT 1 - ANALYSIS OF COMPLIANCE WITH ZONING REQUIREMENTS

20.12 Zoning Districts and Permitted Uses

General Plan: Low Density Residential
 Zoning: R-1 - Single-Family Residential

20.16 Land Use Classifications

Single family residential

Surrounding North - SFR East - SFR
 Property Use South - SFR West - SFR

20.20.080 Secondary Residential Units.

Not applicable.

20.24.020 Table of Site Regulations by District.

	Existing (approx.)	Proposed (approx.)	Requirement
Setbacks			
Front (west)	17' 6"	No change	15'
Side (south)	5'	No change	3' 6"
Side (south)	4'	No change	3' 6"
Rear (west)	41'	No change	20'
Area			
Lot Size	3,850	No change	--
Lot Coverage	34%	34%	50%
Maximum Height	20' 8"	23' 5"	28' max.

20.24.030 Overlay District Regulations.

Not applicable.

20.24.040 Hillside Residential Regulations.

Not applicable.

20.24.050 Floor-Area-Ratio.

	Existing (approx.)	Proposed	Requirement
Lot Size	3,850	No change	--
Floor Area			
Garage	370	310	
First-floor	465	738	--
Second-floor	1,193	1,170	
Total	2,028	2,218	--
Total Counted	1,808	1,998	--
Floor Area Ratio	47%	52%	55%

* 220 sq. ft. exempted from "total counted" as permitted by MC 20.24.050 for enclosed parking spaces.

20.24.060 Setback Areas, Encroachments.

Not applicable.

20.24.100 Distances between Structures.

Not applicable.

20.24.110 Fences, Landscaping, Screening.

Not applicable.

20.24.130 Accessory Buildings.

Not applicable.

20.28 Off-Street Parking Requirement.

Not applicable.

20.40 Housing Provisions

Not applicable.

20.44 Non-conforming Uses, Structures and Lot

Not applicable.

20.48 Removal of Trees

Not applicable.

20.52 Flood Damage Prevention Regulations

Not applicable.

20.100.030 Use Permits.

Not applicable.

20.100.040 Variances.

Not applicable.

20.100.010 Common Permit Procedures.

Public notice of this application was mailed on February 12, 2010, in the form of mailed notice, to property owners and occupants within a 100-foot radius, and posted in three locations.

20.100.050 Design Review.

See Summary of Key Issues.

ATTACHMENT - 3

FINDINGS AND CONDITIONS OF APPROVAL

Findings for Design Review approval (Per section 20.100.050.E of the AMC)

Required Finding	Explanation
<p>1. <i>The project conforms to the General Plan, any applicable specific plan, applicable design guidelines adopted by the City of Albany, and all applicable provisions of this Chapter.</i></p>	<p>The General Plan designates this area for residential development. Additionally, the project meets City zoning standards for location, intensity and type of development.</p>
<p>2. <i>Approval of project design is consistent with the purpose and intent of this section, which states "designs of projects...will result in improvements that are visually and functionally appropriate to their site conditions and harmonious with their surroundings, including natural landforms and vegetation. Additional purposes of design review include (but are not limited to): that retention and maintenance of existing buildings and landscape features are considered; and that site access and vehicular parking are sufficient."</i></p>	<p>The proposal is in scale and harmony with existing development in the vicinity of the site. The architectural style, design and building materials are consistent with the existing dwelling and with the City's Residential Design Guidelines. The proposed project will provide safe and convenient access to the property for both vehicles and pedestrians. The project will maintain the primary trees on the site and will not require significant grading. The project will create attractive new entrance to the residence.</p>
<p>3. <i>Approval of the project is in the interest of public health, safety and general welfare.</i></p>	<p>The proposed project will not be detrimental to the health, safety, convenience and welfare of those in the area and would not adversely impact property, improvements or potential future development in the area. The project will include removal of vinyl siding and upgrade the structural strength of the residence.</p>
<p>4. <i>The project is in substantial compliance with applicable general and specific Standards for Review stated in Subsection 20.100.050.D.</i></p>	<p>The project as designed is in substantial compliance with the standards as stated, including access, architecture, natural features, coordination of design details, retention and maintenance of buildings, and privacy.</p>

CONDITIONS OF APPROVAL

GENERAL PROJECT CONDITIONS

- Gen-1 **Project Approval.** This Design Review approval is for Michael Massoumi, as substantially shown and described on the project plans prepared by Samonsky & Pometta, date received January 19, 2010, except as modified herein. For any condition herein that requires preparation of a Final Plan where the project developer has submitted a conceptual plan, the project developer shall submit final plan(s) in substantial conformance with the conceptual plan, but incorporate the modifications required by the conditions herein for approval by the City.
- Gen-2 **Project Approval Expiration.** This Design Review approval expire on March 9, 2011 (one year from the date on which this approval becomes effective) or at an alternate time specified as a condition of approval, unless a building permit has been issued and construction diligently pursued; a certificate of occupancy has been issued; the use is established; the use permit, variance or design review approval is renewed]. The approval may be renewed by the Community Development Director for a period up to an additional two (2) years, provided that, at least ten (10) days before expiration of one (1) year from the date when the approval becomes effective, an application for renewal of the approval is filed with the Community Development Department. The Community Development Director may grant a renewal of an approval where there is no change in the original application, or there is no request to change any condition of approval.
- Gen-3 **Fees.** The applicant shall pay any and all City and other related fees applicable to the property, as may be modified by conditions herein. Fees shall be based on the current fee structure in effect at the time the relevant permits are secured, and shall be paid before issuance of said permit or before any City Council final action approval. Notice shall be taken specifically of Plan Check, Engineering, Fire and Inspection Fees. The project developer shall also reimburse the City for direct costs of planning; building and engineering plan check and inspection, as mutually agreed between the City and developer.
- Gen-4 **Appeals.** The Albany Municipal Code provides that any action of the Planning staff may be appealed to the Planning and Zoning Commission, and any action of the Planning and Zoning Commission may be appealed to the City Council as per the procedures described in Section 20.100.080. The City Clerk will then schedule the matter for the next available City Council meeting.
- Gen-5 **Requirement for Building Permit.** Approval granted by the Planning and Zoning Commission does not constitute a building permit or authorization to begin any construction or demolish an existing structure. An appropriate permit issued by the Community Development Department must be obtained before constructing, enlarging, moving, converting, or demolishing any building or structure within the City.

- Gen-6 **Fire Department Approval.** As part of a building permit application, the applicant shall submit written documentation that all requirements of the Albany Fire Department have, or will be, met to the satisfaction of the AFD.
- Gen-7 **Engineering Approval.** As part of a building permit application, the applicant shall submit written documentation that all requirements of the Public Works Department have, or will be, met to the satisfaction of the City Engineer.
- Gen-8 **Construction Hours.** Construction activity shall be restricted to the hours of 8:00 a.m. to 6:00 p.m. Mondays through Saturdays, and 10:00 a.m. to 6:00 p.m., Sundays and legal holidays, unless otherwise approved in writing by the City Engineer for general construction activity. Failure to comply with construction hours may result in stop work orders or other administrative actions.
- Gen-9 **Archeological Remains.** In the event subsurface archeological remains are discovered during any construction or preconstruction activities on the site, all land alteration work within 100 feet of the find shall be halted, the Community Development Department notified, and a professional archeologist, certified by the Society of California Archeology and/or the Society of Professional Archeology, shall be notified. Site work in this area shall not occur until the archeologist has had an opportunity to evaluate the significance of the find and to outline appropriate mitigation measures, if deemed necessary. If prehistoric archeological deposits are discovered during development of the site, local Native American organizations shall be consulted and involved in making resource management decisions.
- Gen-10 **Modifications to Approved Plans.** The project shall be constructed as approved. Planning staff may approve minor modifications in the project design, but not the permitted land use (per Albany Municipal Code 20.12). A change in an item requiring discretionary approval and any other changes deemed appropriate by the Planning staff shall require further Planning and Zoning Commission approval through the Design Review process.
- Gen-11 **Hold Harmless Agreement.** Pursuant to Government Code Section 66474.9, the applicant (including any agent thereof) shall defend, indemnify, and hold harmless, the City of Albany and its agents, officers and employees, from any claim, action, or proceeding against the City or its agents, officers or employees to attack, set aside, void, or annul the City's approval concerning this application, which action is brought within the time period provide for in Section 66499.37. The City will promptly notify the applicant of any such claim action or proceeding and cooperate fully in the defense.
- Gen-12 **Public Improvements Standards.** Public improvements shall be designed and constructed in accordance with the City's Standard Specifications and Standard Details, unless specifically waived in writing by the City Engineer.
- Gen-13 **Title 24 Standards.** All construction shall be designed and built in accordance with California Title 24 handicap accessibility standards. Appropriate details and

specifications shall be incorporated into the plans and submitted at time of building permit application.

- Gen-14 **Energy Conservation Standards.** All buildings shall be designed in accordance with the State of California energy conservation standards for residential buildings. The necessary plans and documentation shall be submitted at time of building permit application.

ARCHITECTURAL CONDITIONS

- Arch-1 **Material Samples.** Samples of final exterior materials and the proposed color palette shall be submitted for review and approval by the Community Development Department as part of building permit application.
- Arch-2 **Final Architectural Drawings.** The applicant shall submit final architectural elevations, details and revisions for the review and approval of the Community Development Department as part of building permit application.
- Arch-3 **Window Recess.** All new windows shall be recessed two inches from face of building to provide adequate shade and shadow and to promote visual relief. Final window details shall be submitted for review and approval at the time of building permit application.
- Arch-4 **Non-Reflective Glazing.** Any glazing material shall be non-reflective.

LIGHTING CONDITIONS

- Lght-1 **Exterior Lighting.** All exterior lighting shall be installed in such a manner that glare is directed away from surrounding properties and rights-of-way. If required, exterior light fixtures shall be equipped with "cut off" lenses to minimize light and glare spill over onto adjacent properties.
- Lght-2 **Shielding of Lighting.** Prior to the certificate of occupancy, all accent lighting shall be directed downward and, if necessary, fixed with cut-off lenses to ensure that no glare spills onto neighboring properties.

LANDSCAPING CONDITIONS

- Lndsc-1 **Street Tree Requirement.** The applicant shall apply for one street tree before the issuance of the building permit. The City's Environmental Resource Assistance will determine the type and location of the tree and may waive this requirement if site conditions will not reasonably support establishment of a new tree.

PUBLIC WORKS DEPARTMENT CONDITIONS

General Engineering Conditions

- Engr-1 **Backflow Device.** Any required water service for fire protection purposes shall be equipped with a City approved backflow device. Services for irrigation purposes also require a separate City approved backflow prevention device.

GRADING CONDITIONS

- Grad-1 **Grading Permit.** Any grading required in association with the project shall require a grading permit from the Community Development Department. To obtain this permit, the applicant shall submit a grading plan, indicating the extent and volumes of earth proposed to be moved. A grading permit is subject to 2001 California Building, Appendix 33.
- Grad-2 **Demolition Permit.** Site demolition shall not occur until construction permits are issued for the development project. All demolition shall be in accordance with permits issued by the City and Bay Area Air Quality Management District (BAAQMD).
- Grad-3 **Water on Site.** The site shall be graded so as to prevent rainfall runoff originating from improved areas on the project site from crossing onto adjoining private property. Building floor elevations shall be above the FEMA-mapped 100-year flood plain as established by a licensed civil engineer. Provide the elevation and compaction certificates during and upon the completion of grading required by the California Building Code and in conformance with the recommendations of the geotechnical engineer's report. Shore and dewater all excavations in accordance with the requirements of the geotechnical engineer's report.
- Grad-4 **Flooding Damages.** The project developer shall execute an assumption of risk, indemnification and hold harmless agreement as required by the City. The agreement, in substance, shall state that the project developer, and any successor in interest, shall assume all risk for damages to the project and to project improvements, flooding caused by surface water intrusion, stormwater runoff, or water under the ground surface pressing on or flowing or seeping through foundations, walls, floors, or paved surfaces, basements, whether paved or not, or windows, doors or other openings, and shall indemnify and hold the City harmless from any claims of such damages, including third-party claims, of such damage or of such damages or of damages arising from rainfall runoff which is not prevented from leaving the project site in violation of Condition GRAD-3.
- Grad-5 **Dust Control Program.** A dust control program shall be prepared by the project developer and approved by the Community Development Department and City Engineer before issuance of a grading permit. The dust control plan shall address such items as covering stockpiled material, frequent watering of graded areas, revegetating graded areas, speed limits for grading equipment and similar items.

Grad-6 **Stormwater Pollution Prevention Plan.** The project developer shall submit a Stormwater Pollution Prevention Plan (SWPPP) for review by the City before the issuance of a building or grading and/or building permit. The SWPPP shall be consistent with standards adopted by the Regional Water Quality Control Board and the City of Albany Clean Water Program and implemented by the project general contractor, all subcontractors and suppliers of material and equipment. Construction site cleanup and control of construction shall also be addressed in the SWPPP. The project developer shall be responsible for SWPPP compliance. A copy of the SWPPP shall be kept at the construction site at all times.

INFRASTRUCTURE CONDITIONS

- Infr-1 **Sewer System Requirements.** The sewer system for the subject building shall comply with Chapter 15 of the Albany Municipal Code and to the satisfaction of the City Engineer before Final Inspection approval of the construction permit.
- Infr-2 **Two-Way Cleanout.** Installation of a two-way curbside cleanout shall be required per Chapter 15 of the Albany City Code. This applies to all properties, including properties with a valid upper sewer lateral certificate of compliance. All 2-way curbside clean outs shall be fitted with a loose cap in accordance with the City's standard detail SS6.
- Infr-3 **Property Run-off Requirements.** All runoff from impervious surfaces shall be intercepted at the project boundary and shall be collected and conducted via an approved drainage system through the project site to an approved storm drain facility, as determined by the City Engineer. Development that contributes additional water to the existing drainage system shall be required to complete a hydraulic study and make improvements to the system as required to accommodate the expected ultimate peak water flow and to stabilize erosive banks that could be impacted by additional storm water flow.
- Infr-4 **Roof Drainage.** Roof drainage from the structure shall be collected via a closed pipe and conveyed to an approved storm drain system off the street curb. No concentrated drainage of surface flow across sidewalks shall be permitted. Alternative natural treatment measures are subject review and approval by the City Engineer.
- Infr-5 **Completion of Off-Site Improvements.** Off-site improvements, as required by the City Engineer, shall be complete before issuance of a Certificate of Occupancy unless alternatives are approved in writing by the Albany City Engineer.

PUBLIC IMPROVEMENTS CONDITIONS

- Pubim-1 **Encroachment Permit.** The applicant shall obtain an encroachment permit from the Engineering Division before commencing any construction activities within any public right-of-way or easement.

- Pubim-2 **Debris Removal.** All mud, dirt or construction debris carried off the construction site onto adjacent streets shall be removed each day. No materials shall be discharged onto a sidewalk, street, gutter, storm drain or creek.
- Pubim-3 **Damage to Street Improvements.** Any damage to street improvements now existing or done during construction on or adjacent to the subject property, shall be repaired to the satisfaction of the City Engineer at the full expense of the applicant. This shall include sidewalk repair, slurry seal, street reconstruction or others, as may be required by the City Engineer.
- Pubim-4 **Right-of-Way Construction Standards.** All improvements within the public right-of-way, including curb, gutter, sidewalks, driveways, paving and utilities, shall be reconstructed in accordance with approved standards and/or plans and shall comply with the standard plans and specification of the Community Development Department and Chapter 14 of the City Code.

FIRE DEPARTMENT CONDITIONS

- Fire-1 **Construction of 1,500 Square Feet or Greater.** 1500 sq. ft. or more or any addition, remodel, rehabilitation, etc. is 50% of the existing sq. ft.:
- a) This dwelling will be required install an Automatic Fire Extinguishing System throughout the entire dwelling. Ordinance No. 94-010, Albany Municipal Code, Chapter 11, Section 11-2.3a(3)(a).
 - b) Plans, information sheets on all sprinkler components and hydraulic calculations are required.
 - c) A 110-volt interconnected smoke alarm system with a 10-year lithium battery back-up is acceptable with a fire suppression system.
- Fire-2 **Fire Rated Construction.** Any portion of a building five (5) feet or less from the property line shall comply with fire-rating requirements of the CBC.
- Fire-3 **Gallons-per-Minute Requirement.** The water system for fire protection shall comply with City of Albany Fire Department standards. Fire flow test data and water system plans must be provided at time of building plan check. The plans must include all equipment, components and layout of the system. Private fire protection water systems shall be supplied through an approved backflow device per City Engineering Division standards.

STRUCTURAL CONTROL MEASURES

- Struc-1 **Illegal Dumping to Storm Drain Inlets and Waterways.** On-site storm drain inlets shall be clearly marked with the words "No Dumping! Flows to Bay," or equivalent, using methods approved by the City of Albany.
- Struc-2 **Pesticide/Fertilizer Application** Landscaping shall be designed to minimize irrigation and runoff, promote surface infiltration where appropriate, and minimize the use of fertilizers and pesticides that can contribute to stormwater pollution. If a landscaping plan is required as part of a development project

application, the plan shall meet the following conditions related to reduction of pesticide use on the project site:

- a) Where feasible, landscaping shall be designed and operated to treat stormwater runoff by incorporating elements that collect, detain, and infiltrate runoff. In areas that provide detention of water, plants that are tolerant of saturated soil conditions and prolonged exposure to water shall be specified.
- b) Plant materials selected shall be appropriate to site specific characteristics such as soil type, topography, climate, amount and timing of sunlight, prevailing winds, rainfall, air movement, patterns of land use, ecological consistency and plant interactions to ensure successful establishment.
- c) Existing native trees, shrubs, and ground cover shall be retained and incorporated into the landscape plan to the maximum extent practicable.
- d) Proper maintenance of landscaping, with minimal pesticide use, shall be the responsibility of the property owner.

OPERATIONAL BEST MANAGEMENT PRACTICES (BMPS)

- Bmp-Gen1 Stormwater Pollution Prevention Control Measures.** The project plans shall include stormwater pollution prevention and control measures for the operation and maintenance of the project during and after construction for the review and approval of the City or County Engineer. The project plan shall identify Best Management Practices (BMPs) appropriate to the uses conducted on-site in order to limit to the maximum extent practicable the entry of pollutants into stormwater runoff.
- Bmp-Gen2 Erosion Control Measures.** The project plan shall also include erosion control measures to prevent soil, dirt and debris from entering the storm drain system, in accordance with the practices outlined in the ABAG *Erosion and Sediment Control Handbook*, California Storm Water Best Management Practice Handbooks, and Regional Water Quality Control Board's *Erosion and Sediment Control Field Manual*
- Bmp-Gen3 Responsibility of Contractors.** The applicant is responsible for ensuring that all contractors and subcontractors are aware of and implement all stormwater quality control measures. Failure to comply with the approved construction BMPs shall result in the issuance of correction notices, citations and/or a project stop order.
- Bmp-1 Paved Sidewalks and Parking Lots.** Sidewalks and parking lots shall be swept regularly to prevent the accumulation of litter and debris. Debris resulting from pressure washing shall be trapped and collected to prevent entry into the storm drain system. Washwater containing any soap, cleaning agent or degreaser shall be collected and discharged to the sanitary sewer and shall not be discharged to a storm drain. The applicant shall contact the City Engineer for specific connection and discharge requirements.

Bmp-2a **Private Streets, Utilities and Common Areas.** The owner of private streets and storm drains shall prepare and implement a plan for street sweeping of paved private roads and cleaning of all storm drain inlets.

GENERAL CONSTRUCTION BEST MANAGEMENT PRACTICES (BMPS)

Bmp-Cnst1 **Construction Access Routes.** Construction access routes shall be limited to those approved by the City Engineer and shall be shown on the approved grading plan.

Bmp-Cnst2 **Collection of Construction Debris.** Gather all construction debris on a regular basis and place them in a dumpster or other container which is emptied or removed on a weekly basis. When appropriate, use tarps on the ground to collect fallen debris or splatters that could contribute to stormwater pollution.

Bmp-Cnst3 **Removal of Waste.** Remove all dirt, gravel, rubbish, refuse and green waste from the sidewalk, street pavement, and storm drain system adjoining the project site. During wet weather, avoid driving vehicles off paved areas and other outdoor work.

Bmp-Cnst4 **Sweeping of Public Right-of-Way.** Broom sweep the sidewalk and public street pavement adjoining the project site on a daily basis. Caked on mud or dirt shall be scraped from these areas before sweeping.

Bmp-Cnst5 **Filter Materials at Storm Drain Inlet.** Install filter materials (such as sandbags, filter fabric, etc.) at the storm drain inlet nearest the downstream side of the project site prior to:

- a) start of the rainy season (October 1);
- b) site dewatering activities;
- c) street washing activities;
- d) saw cutting asphalt or concrete; and
- e) order to retain any debris or dirt flowing into the City storm drain system.

Filter materials shall be maintained and/or replaced as necessary to ensure effectiveness and prevent street flooding. Dispose of filter particles in the trash.

Bmp-Cnst6 **Containment of Materials.** Create a contained and covered area on the site for the storage of bags of cement, paints, flammables, oils, fertilizers, pesticides, or any other materials used on the project site that have the potential for being discharged to the storm drain system by wind or in the event of a material spill.

Bmp-Cnst7 **Cleaning of Equipment.** Never clean machinery, tools, brushes, etc. or rinse containers into a street, gutter, storm drain or stream. See the *Building Maintenance/ Remodeling* flyer for more information.

Bmp-Cnst8 **Minimize Removal of Natural Vegetation.** Minimize removal of natural vegetation or ground cover from the site in order to minimize the potential for erosion and sedimentation problems. Replant the area as soon as possible. All cut

and fill slopes shall be stabilized as soon as possible after grading is completed. No site grading shall occur between October 1 and April 15 unless approved erosion and sedimentation control measures are in place.

Appeals: The Albany Municipal Code provides that any action of the Planning and Zoning Commission may be appealed to the City Council, if such appeal is filed within 14 days of the date of the action. Appeals may be filed in the Community Development Department by completing the required form and paying the required fee. The City Clerk will then schedule the matter for the next available City Council meeting.



City of Albany



PLANNING APPLICATION FORM FOR DESIGN REVIEW AND CONDITIONAL USE PERMITS FOR SINGLE FAMILY RESIDENTIAL ADDITIONS

For PLANNING & ZONING COMMISSION action:	
<input checked="" type="checkbox"/> Design Review - residential additions or exterior modifications.	\$560* / Admin. \$400*
<input type="checkbox"/> Parking Exceptions/Reductions - see separate handout	\$620*
<input type="checkbox"/> Conditional Use Permit - Non-Conforming Wall(s)	\$1110

* When obtaining more than one planning approval, the full amount for the highest fee will apply and 1/2 fee will be charged for any other ones.

The City of Albany Municipal Code has certain requirements for approving Design Review of additions to Single Family Residences. Please complete the following application to initiate the process. Please be aware that staff may have additional questions for you based on your responses. You should anticipate that planning staff and/or Planning and Zoning Commissioners will visit your site prior to your Planning and Zoning Commission meeting.

Job Site Address: 1014 ORDWAY AVENUE		Zone: (R1) R2 R3 R4 Other overlays:
Property Owner(s) Name: MICHAEL MASSOUMI	Phone: 510-381-0677 Fax: 510-841-6423	Email: m.massoumi@aol.com
Mailing Address: 1014 ORDWAY AVENUE	City: ALBANY	State/Zip: CA 94706
Applicant(s) Name (contact person): SAME AS OWNER	Phone: Fax:	Email:
Mailing Address:	City:	State/Zip:

GENERAL INFORMATION (Please fill out this Chart - existing & proposed.)

Item	Existing	Proposed
How big is your lot? Express in square feet.	3850	3850
What is the floor area of: your existing residence (see additional handout on how to measure this)	1808	1998
any detached buildings--garage, sheds, etc.	NO	NO
How many square feet is your addition?	N/A	190
What is the Floor Area Ratio (FAR) ¹ (see additional handout on how to measure this)	47%	52%
What is your lot coverage? ²	31%	34%
What is the amount of impervious surface on the lot?	395	580
What is the maximum height of your residence?	16'-8"	23'-8"
How many dwelling units are on your site?	1	1
How many parking spaces do you have in a garage? ³	1	1
What are the interior dimensions of your garage?	12x25'	10x19'
What is the narrowest width of your driveway?	10'	12'

Structs:			
Front yard: What is the minimum distance between the front wall of your house and the front property line?		17'-6"	17'-6"
Side yard: What is the shortest distance between a side wall of your house and a side property line?		6'-1"	6'-1"
Rear yard: What is the minimum distance between the rear wall of your house and the rear property line?		41'-5"	41'-0"
Grade (street only): What is the slope of your lot?		5%	5%

Notes:

1. Floor Area Ratio (FAR) applies to single family residential development in all zones. It is defined as the ratio between the gross floor area of a building(s) on a lot compared to gross square feet of lot (see the definition).
2. Lot Coverage is defined as the land area covered by all structures except uncovered decks, porches, balconies, balconies or structures that are less than 6 feet above grade as well as eaves, trellises and similar structures that do not have solid roofs.
3. The Albany Municipal Code requires that every residential unit must have 2 off-street parking spaces. Some exceptions may apply in your situation. See the parking section of the Zoning Ordinance for a complete list of possible exceptions.

(Please use additional sheets to explain any of your responses to the following).

1. Will the construction of the addition require the removal of any mature trees? No
If yes, please describe: _____
2. Are the architecture, materials and colors of the proposed addition consistent with the existing dwelling?
YES
If yes, please describe how: STUCCO WALLS, SPANISH-CLAY TILE ROOF, WOOD DOORS
3. Is the proposed addition sensitive to the size or mass of the surrounding properties? YES
If yes, please describe how: THE HOUSE REMAINS 2 STORIES IN A HEIGHT OF 12'0"
4. If you have no garage, where do you park vehicles? THERE IS A GARAGE

Story Poles - For new residential construction and exterior alterations that increase the height, an applicant is required to erect at least two "story poles", a temporary construction for the purpose of visually displaying the outer limits, including the height, of the proposed structural alterations. These poles shall be erected at least ten (10) days prior to the design review meeting, and shall be maintained in place through the date of the meeting.

The signature of the property owner is required for all projects. By executing this form you are affirming that you are the property owner.

Signature of Property Owner Date

Phil [Signature] 6/19/10
Signature of Applicant (if different) Date

City Planning Department staff is available Monday, 8:30 AM to 7:00 PM, Tuesday through Thursday 9:00 AM to 5:00 PM, and Friday 9:00 AM to 12:30 PM at 1000 San Pablo Avenue, Albany, CA 91706 (530) 523-5760.

JAN 19 2010

COMMUNITY DEVELOPMENT
DEPARTMENT



City of Albany

Green Building Program Rating System for Remodeling Projects* Supplemental Application Form

*Please obtain other appropriate Green Point Checklist for projects other than Single Family Residential Remodeling Projects

Project Address: 1014 ORDWAY AVENUE
 Checklist Prepared By: GARY SAMONSKY ARCHITECT
 Date Prepared: 01-19-10

	INPUT	Resources	Energy	IAQ/Health
--	-------	-----------	--------	------------

A. Site

1. Recycle Job Site Construction & Demolition Waste 65% = 1 point; 75% = 2 points; 80% = 4 points	up to 4 Resource pts	Y	1		
2. Salvage Reusable Building Materials	4 Resource pts	y=yes	4		
3. Remodel for Mixed Use, Adaptive Reuse, and Historic Preservation	4 Resource pts	y=yes			
4. Protect Native Soil	2 Resource pts	y=yes			
5. Minimize Disruption of Existing Plants & Trees	1 Resource pt	y=yes	1		
6. Implement Construction Site Stormwater Practices	2 Resource pts	y=yes	2		
7. Protect Water Quality with Landscape Design	2 Resource pts	y=yes			
8. Design Resource-Efficient Landscapes and Gardens	4 Resource pts	y=yes	4		
9. Reuse Materials/Use Recycled Content Materials for Landscape Areas	2 Resource pts	y=yes			
10. Install High-Efficiency Irrigation Systems	2 Resource pts	y=yes			
11. Provide for On-Site Water Catchment / Retention	2 Resource pts	y=yes			

B. Foundation

1. Incorporate Recycled Flyash in Concrete 25% Recycled Flyash = 2 points; Add 1 point for every 10% increase of flyash, up to 5 points	up to 5 Resource pts	Y	2		
2. Use Recycled Content Aggregate	2 Resource pts	y=yes			
3. Insulate Foundation/Slab before backfill	3 Energy pts	y=yes	3		

C. Structural Frame

1. Substitute Solid Sawn Lumber with Engineered Lumber	3 Resource pts	y=yes	3		
2. Use FSC Certified Wood for framing (For every 10% of FSC lumber used = 2 points, up to 10)	up to 10 Resource pts.	Y	4		
3. Use Wood I-Joists for Floors and Ceilings	2 Resource pts	y=yes			
4. Use Web Floor Trusses / ROOF	2 Resource pts	y=yes	2		
5. Design Energy Heels on Trusses 6" or more	2 Energy pts	y=yes	2		
6. Use Finger-Jointed Studs for Vertical Applications	2 Resource pts	y=yes			
7. Use Engineered Studs for Vertical Applications	2 Resource pts	y=yes			
8. Use Recycled Content Steel Studs for Interior Framing	2 Resource pts	y=yes			
9. Use Structural Insulated Panels (SIPs)					
a. Floors	3 Energy pts	y=yes			
b. Wall	3 Energy pts	y=yes			
c. Roof	3 Energy pts	y=yes			

			INPUT	Resources	Energy	IAQ/Health
10. Apply Advanced Framing Techniques	4 Resource pts	y=yes				
11. Use Reclaimed Lumber for Non Structural Applications	3 Resource pts	y=yes				
12. Use OSB						
a. Subfloors	1 Resource pt	y=yes	Y	1		
b. Sheathing	1 Resource pt	y=yes	Y	1		

D. Exterior Finish

1. Use Sustainable Decking Materials						
a. Recycled content	3 Resource pts	y=yes				
b. FSC Certified Wood	3 Resource pts	y=yes				
2. Use Treated Wood That Does Not Contain Chromium/Arsenic	1 IAQ/Health pt	y=yes	Y			1
3. Install House Wrap under Siding	1 IAQ/Health pt	y=yes	Y			1
4. Use Fiber-Cement Siding Materials	1 Resource pt	y=yes				

E. Plumbing

1. Install Water Heater Jacket	1 Energy pt	y=yes				
2. Insulate Hot and Cold Water Pipes	2 Energy pts	y=yes	Y	2		
3. Retrofit all Faucets and Showerheads with Flow Reducers						
a. Faucets (1 point each, up to 2 points)	Up to 2 Resource pts.		Y	2		
b. Showerheads (1 point each, up to 2 points)	Up to 2 Resource pts.		Y	2		
4. Replace Toilets with Ultra-Low Flush Toilets (1 point each, up to 3 points)	Up to 3 Resource pts.		Y	3		
5. Install Chlorine Filter on Showerhead	1 IAQ/Health pt	y=yes				
6. Convert Gas to Tankless Water Heater	4 Energy pts	y=yes	Y	4		
7. Install Water Filtration Units at Faucets (2 points each, up to 4 points)	Up to 4 IAQ/Health pts.					
8. Install On-Demand Hot Water Circulation Pump	4 Resource pts	y=yes				

F. Electrical

1. Install Compact Fluorescent Light Bulbs (CFLs) (6 bulbs=2 points, 10 bulbs =3 points, 12 bulbs = 4 points)	Up to 4 Energy pts.		Y	4		
2. Install IC-AT Recessed Fixtures with CFLs (1 point each, up to 5 points)	Up to 5 Energy pts.		Y	5		
3. Install Lighting Controls (1 point per fixture, up to 4 points)	Up to 4 Energy pts.		Y	4		
4. Install High Efficiency Ceiling Fans with CFLs (1 point each, up to 4 points)	Up to 4 Energy pts.					

G. Appliances

1. Install Energy Star Dishwasher	1 Energy pt	y=yes	Y		1	
2. Install Washing Machine with Water and Energy Conservation Features	1 Energy pt	y=yes	Y		1	
3. Install Energy Star Refrigerator	1 Energy pt	y=yes	Y		1	
4. Install Built-In Recycling Center	3 Resource pts	y=yes	Y	3		

H. Insulation

1. Upgrade Insulation to Exceed Title 24 Requirements						
a. Walls	2 Energy pts	y=yes	Y		2	
b. Ceilings	2 Energy pts	y=yes	Y		2	

			INPUT	Resources	Energy	IAQ/Health
2. Install Floor Insulation over Crawl Space	4 Energy pts	y=yes	Y		4	
3. Install Recycled-Content, Fiberglass Insulation with No Added Formaldehyde	3 IAQ/Health pts	y=yes				
4. Use Advanced Infiltration Reduction Practices	2 Energy pts	y=yes	Y		2	
5. Use Cellulose Insulation						
a. Walls	4 Resource pts	y=yes				
b. Ceilings	4 Resource pts	y=yes				
6. Alternative Insulation Products (Cotton, spray-foam)						
a. Walls	4 Resource pts	y=yes	Y	4		
b. Ceilings	4 Resource pts	y=yes	Y	4		

I. Windows

1. Install Energy-Efficient Windows						
a. Double-Paneled	1 Energy pt	y=yes	Y		1	
b. Low-Emissivity (Low-E)	2 Energy pts	y=yes	Y		2	
c. Low. Conductivity Frames	2 Energy pts	y=yes	Y		2	
2. Install Low Heat Transmission Glazing	1 Energy pt	y=yes				

J. Heating Ventilation and Air Conditioning

1. Use Duct Mastic on All Duct Joints	2 Energy pts	y=yes	Y		2	
2. Install Ductwork within Conditioned Space	3 Energy pts	y=yes	Y		3	
3. Vent Range Hood to the Outside	1 IAQ/Health pt	y=yes	Y			1
4. Clean all Ducts Before Occupancy	2 IAQ/Health pts	y=yes	Y			2
5. Install Solar Attic Fan	2 Energy pts	y=yes				
6. Install Attic Ventilation Systems	1 Energy pt	y=yes				
7. Install Whole House Fan	4 Energy pts	y=yes				
8. Install Sealed Combustion Units						
a. Furnaces	3 IAQ/Health pts	y=yes	Y			3
b. Water Heaters	3 IAQ/Health pts	y=yes	Y			3
9. Replace Wall-Mounted Electric and Gas Heaters with Through-the-Wall Heat Pumps	3 Energy pts	y=yes				
10. Install 13 SEER/11 EER or higher AC with a TXV	3 Energy pts	y=yes				
11. Install AC with Non-HCFC Refrigerants	2 Resource pts	y=yes				
12. Install 90% Annual Fuel Utilization Efficiency (AFUE) Furnace	2 Energy pts	y=yes	Y		2	
13. Retrofit Wood Burning Fireplaces						
a. Install EPA certified wood stoves/inserts	1 IAQ/Health pt	y=yes				
b. Install/Replace Dampers	1 Energy pt	y=yes				
c. Install Airtight Doors	1 Energy pt	y=yes				
14. Install Zoned, Hydronic Radiant Heating	3 Energy pts	y=yes				
15. Install High Efficiency Filter	4 IAQ/Health pts	y=yes				
16. Install Heat Recovery Ventilation Unit (HRV)	5 IAQ/Health pts	y=yes				
17. Install Separate Garage Exhaust Fan	3 IAQ/Health pts	y=yes				

K. Renewable Energy and Roofing

1. Pre-Plumb for Solar Water Heating	4 Energy pts	y=yes				
2. Install Solar Water Heating System	10 Energy pts	y=yes				
3. Pre-Wire for Future Photovoltaic (PV) Installation	4 Energy pts	y=yes				
4. Install Photovoltaic (PV) System (1.2 kw = 6 points, 2.4 kw = 12 points, 3.6 kw = 18 points)	Up to 18 Energy pts					

			INPUT	Resources	Energy	IAQ/Health
6. Select Safe and Durable Roofing Materials	1 Resource pt	y=yes	Y	1		
7. Install Radiant Barrier	3 Energy pts	y=yes				
L. Natural Heating and Cooling						
1. Incorporate Passive Solar Heating	5 Energy pts	y=yes				
2. Install Overhangs or Awnings over South Facing Windows	3 Energy pts	y=yes	Y		3	
3. Plant Deciduous Trees on the West and South Sides	3 Energy pts	y=yes				
M. Indoor Air Quality and Finishes						
1. Use Low/No-VOC Paint	1 IAQ/Health pts	y=yes	Y			1
2. Use Low VOC, Water-Based Wood Finishes	2 IAQ/Health pts	y=yes	Y			2
3. Use Low/No VOC Adhesives	3 IAQ/Health pts	y=yes	Y			3
4. Use Salvaged Materials for Interior Finishes	3 Resource pts	y=yes				
5. Use Engineered Sheet Goods with no added Urea Formaldehyde	6 IAQ/Health pts	y=yes	Y			6
6. Use Exterior Grade Plywood for Interior Uses	1 IAQ/Health pts	y=yes	Y			1
7. Seal all Exposed Particleboard or MDF	4 IAQ/Health pts	y=yes				
8. Use FSC Certified Materials for Interior Finish	4 Resource pts	y=yes				
9. Use Finger-Jointed or Recycled-Content Trim	1 Resource pts	y=yes	Y	1		
10. Install Whole House Vacuum System	3 IAQ/Health pts	y=yes				
N. Flooring						
1. Select FSC Certified Wood Flooring	8 Resource pts	y=yes				
2. Use Rapidly Renewable Flooring Materials	4 Resource pts	y=yes	Y	4		
3. Use Recycled Content Ceramic Tiles	4 Resource pts	y=yes				
4. Install Natural Linoleum in Place of Vinyl	5 IAQ/Health pts	y=yes				
5. Use Exposed Concrete as Finished Floor	4 Resource pts	y=yes				
6. Install Recycled Content Carpet with Low VOCs	4 Resource pts	y=yes				
O. City of Albany Incentives						
1. Additions less than 50% increase in floor area	20 Resource pts	y=yes	Y	20		
2. Additions less than 200sq.ft. or resulting in less than 1,500sq.ft.	10 Resource pts	y=yes				
3. Seismic upgrade of existing building	25 Resource pts	y=yes	Y	25		
4. For having a hybrid or zero emissions vehicle	2 IAQ/Health pts	y=yes				
5. For having no automobile	5 Resource pts	y=yes				
6. Plant more than one street tree when feasible	2 IAQ/Health pts	y=yes				
7. Earthquake kit	2 IAQ/Health pts	y=yes	Y			2
TOTAL POINTS ACCUMULATED:			50 points total Req'd			
(50 Points REQUIRED from all 3 columns)						